



WarmingUp 2A: How low can you go?

Online TUDelft Urban Energy Lecture

April 13th, 2022

Ivo.Pothof@deltares.nl

Overview

WARMING^{UP}

- Intro WarmingUP national R&D programme
- Project 2A How low can you go?



Grand challenge

WARMING^{UP}


- **NL: district heating revolution**
 - from 340.000 to 1.1 million dwellings in 2030
- **Decarbonise district heating** via aquathermia, geothermal energy, waste heat and storage
 - 70% CO₂-reduction in 2030 compared to NG-boiler
- **Acceptable and affordable** system and process innovations in supply chain.
 - 1,5% efficiency gain per year



Coherence



WARMING^{UP}



Partners and associate partners

The image displays a collection of logos for various organizations, including:

- Government and Municipalities:** Gemeente Almere, Gemeente Utrecht, Gemeente Rotterdam, Gemeente Breda, provincie HOLLAND ZUID, provincie limburg, HOLLAND RIJNLAND, WARM in de WIJK, THE GREEN VILLAGE, Gemeente Amsterdam (marked with red X's).
- Universities and Research:** Erasmus ERASMUS UNIVERSITEIT ROTTERDAM, TU Delft, TU/e, Universiteit Utrecht, Saxion, Eneco.
- Water and Energy:** UNIE VAN WATERSCHAPPEN, WN, TNO, KWR, VATTENFALL, SVP, Firan, NAT Netwerk Aqua Thermie, ennatuurlijk, ebn, bodem energie nl, KOUWENBERG Infra, thermaflex, Huisman, Platform Geothermie, Feenstra, GREENVIS ENERGY SOLUTIONS, CE Delft, if.
- Engineering and Consulting:** Deltares, Rijkswaterstaat, HVC, Saxon, Tauw, techniplan adviseurs b RAADGEVEND INGENIEURSBUREAU, Rotterdam engineering, B Ware, Ouderzoekcentrum.
- Other:** Stowa, Eneco, Tauw, WARM in de WIJK, if, Cfteling.

39 partners

- DH companies
- Network operators
- Water sector
- Subsurface stakeholders
- Municipalities
- Provinces
- R&D organisations

14 ass. partners

- Network organisations
- Contractors
- Consultants

Innovation plan

- 6 themes, 32 projects, €18,9 M
- 5 PhD's + 1 PDEng, 100+ experts
- Duration 3 years, start 1-1-2020

Funding



- 25% co-funding private and public organisations
- 25% co-funding from R&D organisations
- 50% subsidy from Min. EZK/BZK, grant TEUE819001

How low can you go?

- Hypothesis: many existing heating systems are oversized.
- Motivation
 - Renewable sources and heat pumps like low temperatures
 - Large potential saving to decarbonize heat supply
 - 5 mln existing dwellings x 5 – 10 k€ = 25 – 50 bln.€
 - Very little experimental evidence on reduced supply temperature
- Large-scale measurement campaign in 200 dwellings
 - Collaboration with installation company Feenstra
 - No modification to buildings
- Which fraction of existing dwellings is LT-ready? (LT means $T_s < 55 \text{ }^\circ\text{C}$)
- How low can we go with supply temperature T_s for space heating?



Project plan HLCYG



Contents

WARMING^{UP}


- Measurement set-up
- Method to determine reduced supply temperature
- Representativity of building sample
- Key results



Measurement set-up (1/2)

WARMING^{UP}

- Gas boiler/Building data
 - Thermostat living room indoor temperature (variable)
 - Indoor temperature setpoint (variable)
 - Gas consumption (day) → specific heat demand
- KNMI-data
 - Ambient Temperature (hour)
 - Solar radiation (hour)
- Additional instrumentation near gas boiler
 - Pulse flow meter (10-min)
 - Supply temperature T_s (10-min)
 - Return temperature T_r (10-min)



T_i = indoor temp
 T_s = supply-temperature
 T_r = return-temperature
 T_a = ambient temperature
 M = Mass flow meter (pulse flow meter)
 Q_s = solar heat flux



Measurement set-up (2/2)

- In dwelling 3 temperature sensors and flow meter
- Temperature difference heating system

$$\Delta T_{sys} = T_s - T_r$$

- Temperature difference radiator – living room
 - Log-mean ΔT drives heat transfer


$$\Delta T_{LMTD} = \frac{T_s - T_r}{\ln \left(\frac{T_s - T_i}{T_r - T_i} \right)}$$



- Site visit by Feenstra staff
 - Collect 70 parameters on thermal building specs
 - Assess suitability for participation in measurement campaign
- Reasons to reject dwellings
 - Residents hesitant to collaborate (due to COVID)
 - No free plug for instrumentation
 - Additional heat sources present (fireplace)
 - Poorly accessible radiators for balancing
 - Underfloor heating poorly accessible
- Annual questionnaire
- Periodic thermal comfort questionnaire during heating season


Thermal model calibration

- Lumped model (5 parameters)
 - Heat flow indoor to building envelope (1)
 - Heat flow envelope to outside (2)
 - Solar radiation through windows (3)
 - Total heat supply from radiators
 - Heat capacity living room (4)
 - Heat capacity building envelope (5)
 - Indoor temperature predicted
 - So called 2R-2C model
- Model calibrated to 2 cold 10-day periods and verified on 3rd 10-day period
 - Successful calibration in 187 dwellings
 - Insufficient cold periods this winter



Source: Bacher, Madsen (2011), Identifying suitable models for the heat dynamics of buildings, J. Energy and Buildings 43, 1511-1522



20051101 - 1604h01



Method for reduced design supply temperature

WARMING^{UP}

- Design condition: -10 °C ambient, no solar radiation, +20 °C indoor
 - Daily average condition
- Determine design heat demand Q_d (W) from calibrated model
 - Assuming 18 full load hrs on design day
 - See horizontal lines
- Determine ΔT_{LMTD} and ΔT_{sys} to reach Q_d (kW)
 - Select hourly averaged data points around Q_d
 - Determine 25-percentile in radiator ΔT_{LMTD} at Q_d
 - Determine 25-percentile in van system ΔT_{sys} at Q_d
 - No assumptions required, fully data-driven method





Determination of reduced design supply temperature

- Given $\Delta T_{LMTD,d}$ and $\Delta T_{sys,d}$, reduced design supply temperature

$$T_{s,d} - T_i = \frac{\Delta T_{sys,d}}{1 - e^{-\left(\frac{\Delta T_{sys,d}}{\Delta T_{LMTD,d}}\right)}}$$

$$T_{r,d} = T_{s,d} - \Delta T_{sys,d}$$

- Example dwelling: $T_{s,d} = 59.7 \text{ }^\circ\text{C}$; $T_{r,d} = 40.8 \text{ }^\circ\text{C}$



Is our building sample representative? (1/2)

Period	Detached	Corner	Terraced	Apartement	Total
After 1991	7/8	11/10	17/16	9/12	44/46
1974–1991	6/5	20/13	25/21	14/14	65/53
Before 1974	19/16	28/24	32/28	32/53	111/121
Total	32/29	59/47	74/65	55/79	220/220

- Apartments underrepresented
- Distribution over construction periods reasonably close


Specific heat demand representative? (2/2)

Type	Construction Period	Specific heat demand SH. Source: SDE (PNH), CBS (kWh/m ² /yr)	Specific heat demand in sample (kWh/m ² /yr)
Single family	After 1991	54	105
	1974–1991	75	109
	Before 1974	97	93
Apartement	After 1991	45	92
	1974–1991	70	100
	Before 1974	92	105

- Our sample has larger Spec. Heat demand than average
- Specific heat demand is based on 2021 data
 - KNMI De Bilt 2804 °C*days
 - KNMI Deelen 2976 °C*days
 - +/- 150 °C*days colder than average
- Average construction year is 1998 in category “After 1991”
- Reasonably representative sample


Key results for design condition

- In 60% buildings $T_s < 55\text{ °C}$ (LT-ready)
 - In 80% buildings $T_s < 60\text{ °C}$
 - In 95% buildings $T_s < 70\text{ °C}$
- In 60% woningen: $T_r < 40\text{ °C}$
- In 70% woningen: $10\text{ °C} < T_s - T_r < 20\text{ °C}$
- Only 15% with $T_s - T_r > 20\text{ °C}$



Which 60% of buildings is LT-ready?

- Correlations show that T_s **NOT** related to:
 - Construction period
 - Building type
 - Specific demand space heating
- To do
 - Correlate dimensionless radiator capacity ($Q_d / Q_{\text{installed}}$) or oversizing factor to reduced design supply temperature



Further research

- Extend monitoring campaign to next winter due to mild winter
 - Assess thermal comfort experience in cold ambient conditions
- Quantify minimum supply and return temperature at part-load conditions
- Direct gas savings due to reduced supply temperature
 - Ongoing project with HvA
- 200 calibrated building models
 - Explore flexibility potential during heating season using available thermal mass



Take-away messages

- “Meten is weten” (measure to understand)
- LT (<55°C)-heating requires peak shaving operation
- 60% building stock NL is LT-ready
- Acknowledgements
 - Max Coenen, Lieke vd Most, Martijn Smeulers, Radha Ramoutar, Andrea Forzoni, Tjerk Vreeken, Feenstra BV
- Ivo.Pothof@deltares.nl

